

**Bureau of Buildings
Mississippi State Penitentiary: Water & Wastewater Improvements
Pickering Firm, Inc. Project 25340.01**

Plans, Specifications, and Contract Documents

TO: ALL PLANHOLDERS

FROM: Charles K. Capdepon, III., PE

DATE: Friday, 4 September 2020

The Plans, Specifications, and Contract Documents for this Project shall be amended as follows:

ADDENDUM #2

Project Plans

1. Sheet M7.00: Pump Station Details: Manual Bar Screen

Note 2 reads, "Bar Material: ½" Flat Bar (Stainless Steel)."

Replace with "Bar Material: ½" Flat Bar (Aluminum)."

ITEMS IN CONFLICT WITH THIS ADDENDUM ARE HEREBY DELETED.

THIS ADDENDUM IS MADE PART OF THE SPECIFICATIONS AND CONTRACT DOCUMENTS, AND SHALL BE ACKNOWLEDGED ON THE PROPOSAL AND ON THE BID ENVELOPE.

Pickering Firm, Inc.



**Charles K. Capdepon, III., PE
4 September 2020**