

September 17, 2020

ADDENDUM NUMBER ONE (1)

Project: Roof Replacement
City of Madison
Denson Robinson Public Service Complex
PN: 20035

FROM: Dean and Dean/Associates Architects, P.A.
4400 Old Canton Road, Suite 200
Jackson, MS 39211
(601) 939-7717

The following additions, changes, clarifications and/or substitutions to the Project Drawings as indicated, are hereby made a part of the Contract Documents. Acknowledge receipt of this Addendum by inserting its number and date in the Proposal Form where indicated.

Specifications

- Item #1:** Section 070150 – Preparation for Roofing, paragraph 3.04,C. amend to read as follows:
C. Submittals: The Contractor shall submit an Abatement Plan, Licenses/Certificates of personnel performing the work for each type of hazardous material identified in the Hazardous Materials Surveys.
- Item #2:** Section 075400 – Thermoplastic Membrane Roofing, paragraph 2.03,C. amend to read as follows:
C. Membrane Fastening: Mechanically attached.

END OF ADDENDUM NUMBER ONE (1)

Dean and Dean/Associates
architects p.a.


Kenneth A. Oubre, AIA, Vice President



PLEASE ATTACH THIS ADDENDUM TO THE INSIDE FRONT COVER OF EACH SET OF SPECIFICATIONS.