

ADDENDUM NO.3

06-19-23

IHL#407-002 | UM#19-043 | DD# 2103
UM DATA CENTER
UNIVERSITY OF MISSISSIPPI
UNIVERSITY, OXFORD, MS



NOTICE TO ALL DOCUMENT HOLDERS:

The following additions, changes, and clarifications to the drawings and specifications are to be included as part of the Contract Documents.

SPECIFICATIONS

ITEM NO. 1 SECTION 05 12 00 - STRUCTURAL STEEL FRAMING

This item clarifies erector, fabricator, and detailer qualifications.

ADD the following text at the end of paragraph **1.6,C,1,b**:

“This certification requirement may be relaxed provided that the fabricator can show previous experience with Special Concentrically Braced frame systems (SCBFs) as defined by ASCE 7.”

ADD the following **new** paragraph **1.6,C,1,c**:

“The structural steel fabricator must be registered and approved by the local building official to perform fabrication work without special inspection. Should the fabricator not be so approved, the fabricator shall reimburse the Owner for the cost of the special inspections required by the local building official.”

ADD the following text at the end of paragraph **1.6,C,2,b**:

“This certification requirement may be relaxed provided that the detailer can show previous experience with Special Concentrically Braced frame systems (SCBFs) as defined by ASCE 7.”

ADD the following text at the end of paragraph **1.6,C,3,b**:

“This certification requirement may be relaxed provided that the erector can show previous experience with Special Concentrically Braced frame systems (SCBFs) as defined by ASCE 7.”

ITEM NO. 2 SECTION 23 07 13 - DUCT INSULATION

REPLACE the “3 lb/cu. ft.” in subparagraphs **1. and 2.** of paragraphs **3.11,A through 3.11,R** with the following text:

“1 lb/cu. ft.”

DELETE paragraph **3.12,C** in its entirety.

DELETE paragraph **3.12,D,1** in its entirety.

ITEM NO. 3 SECTION 28 46 21.11 - ADDRESSABLE FIRE-ALARM SYSTEMS

DELETE paragraph **1.05,D** in its entirety.

REPLACE the "Five years" warranty period in paragraph **1.10,A,1** with the following text:

"One year"

DRAWINGS

ITEM NO. 4 SHEET E5.1 - ELECTRICAL RISER

ADD the following note for each static transfer switch:

"Static transfer system is based on Eaton WaveStar STS rated for 1600A or equal."

ADD the following to **KEYED NOTES:**

"Provisions for future shall include capped conduit and pull wire. Feeders are not required to be installed in provisions for future. Feeder sizes are shown for future build-out."

No other items.



Anne Marie Duvall Decker, FAIA

Encs.: See Above

c: 2103.1 Addenda

All Planholders via Jackson Blueprint Plan Room