

BURRIS/WAGNON ARCHITECTS, P.A.

500L EAST WOODROW WILSON AVENUE JACKSON MS 39216 PH 6019697543

17 June 2025

ADDENDUM NO. 2

Re: **Alumni House Exterior Restoration**
Alcorn State University
Lorman, Mississippi
Architect's Project No. 2508

Bid Date: June 20, 2025, 10:00 A.M. CST



NOTICE TO ALL DOCUMENT HOLDERS:

The following additions, changes, and clarifications to the Specifications for the subject project are to be included as part of the Contract Documents, and thus amend the Scope of Work:

SPECIFICATIONS

Item No. 1: Refer to Section 02 08 00, Paragraph 1.2/E/2, and replace with the following:

2. Intact lead-based paint should be retained and encapsulated with compatible primer and finish. Non-abrasive cleaning methods must be used. Hazard reduction on surfaces must be completed with wet scraping, HEPA sanding, or non-caustic strippers.

Item No. 2: Refer to Section 08 01 52.91 Wood Window Restoration (at Addendum #1), Paragraph 1.01/C/3 and change as follows: "Remove all existing loose paint..." See also general paint removal requirements at Section 09 91 00/1.03/A/6 (at Addendum #1), and Item No.1 (above), Addendum #2.

Sincerely,

Bill Burris, AIA
BURRIS/WAGNON ARCHITECTS, P.A.

End of Addendum No. 2