

BURRIS/WAGNON ARCHITECTS, P.A.

500L EAST WOODROW WILSON AVENUE JACKSON MS 39216 PH 6019697543

16 Apr 2026

ADDENDUM NO. 3

Re: **Hangar Door Replacement**
Delta State University
Cleveland, Mississippi
GS# 102-296

Bid Date: Tuesday, April 21, 2026; 2:00 p.m.



NOTICE TO ALL DOCUMENT HOLDERS:

The following additions, changes, and clarifications to the Specifications for the subject project are to be included as part of the Contract Documents, and thus amend the Scope of Work:

SPECIFICATIONS

- Item No. 1:** Refer to Section 05 12 00/1.06 and make the following changes:
- A. Delete paragraphs "A." and "C." in their entirety.
 - B. At Paragraph B, combine first two sentences as follows: " Steel erector or general contractor shall submit the following:" (subparagraphs 1.-5.).
 - C. At paragraph E, delete subparagraph "2."
- Item No. 2:** Refer to Section 07 21 00/2.01, and change 6" thickness to 3" thickness (to be applied to the inside face of the exterior panel).

DRAWINGS:

- Item No. 1:** Refer to Sheet TS, detail "4.", and change 6" sprayed insulation thickness to 3" thickness (to be applied to the interior face of the exterior wall panel).

Sincerely,


Stan Wagon, AIA
BURRIS/WAGNON ARCHITECTS, P.A.

End of Addendum No. 3