

**GS#103-306  
ROOF REPLACEMENTS  
COLLEGE OF EDUCATION & J. Y. WOODARD - PACKAGE 1-R  
JACKSON STATE UNIVERSITY**

**Addendum No. 2 (JYW Package 1-R)**

From: Vernell Barnes, Architect  
1409 Watkins Street  
Natchez, MS 39120  
Telephone: 770.605.9829  
Fax: 770.987.5208

14January2022

**TO: PROSPECTIVE BIDDERS & PLAN ROOMS**

The following additions, changes, clarifications, and substitutions to the specifications and drawings of the original plans and specifications dated October 20, 2021, are to be included as part of the contract documents. Receipt of this addendum shall be acknowledged in the bid proposal form.

**Bid Date:** The bid date, time and location shall remain unchanged.

**GENERAL INFORMATION:**

No items

**REFER TO THE SPECIFICATIONS:**

Item No. 1 Division 7 – 07 7113 Manufactured Copings

Delete: Delete, Part 2.04-A-5 in its entirety.

**ARCHITECTURAL:**

Item No. 1

Clarification: “Two Piece Gravel Stop and Fascia”  
The intent is to retain the lower half (fascia) as shown in the details at all locations around the building and install a new upper half (gravel stop) to match the original material profile, finish and color. Retain the cleats if found to be in good order or replace with new as required by the manufacturer to meet the wind uplift requirements.

End of Addendum Number Two



Vernell E. Barnes, AIA  
Vernell Barnes, Architect

