

**GS#103-306
ROOF REPLACEMENTS
COLLEGE OF EDUCATION & J. Y. WOODARD - PACKAGE 2-R
JACKSON STATE UNIVERSITY**

Addendum No. 2 (COE Package 2-R)

From: Vernell Barnes, Architect
1409 Watkins Street
Natchez, MS 39120
Telephone: 770.605.9829
Fax: 770.987.5208

14January2022

TO: PROSPECTIVE BIDDERS & PLAN ROOMS

The following additions, changes, clarifications, and substitutions to the specifications and drawings of the original plans and specifications dated October 20, 2021, are to be included as part of the contract documents. Receipt of this addendum shall be acknowledged in the bid proposal form.

Bid Date: The bid date, time and location shall remain unchanged.

GENERAL INFORMATION:

No items

REFER TO THE SPECIFICATIONS:

Item No. 1 Division 7 – 07 7113 Manufactured Copings

Delete: Delete, Part 2.04-A-5 in its entirety.

ARCHITECTURAL:

REFER TO THE DRAWINGS:

Item No. 1 Refer to sheets AD-101

Delete Delete the reference in Demolition Key Notes number 3 – To match the Existing Profile and Finish.

Item No. 2 Refer to sheets A-101

Revise Revise note number 3 in Roof Replacement Key Notes to read as follows: Existing metal coping shall be replaced, finish shall match the existing coping.

Item No. 3 Refer to sheets A-501

Delete

Delete all references in details 1 & 2 to: Standing seam to match existing horizontal spacing and profile.

Provide coping joint cover plates 4" minimum to 6" maximum width at coping seams.

End of Addendum Number Two



Vernell E. Barnes, AIA
Vernell Barnes, Architect

