

City of Pearl, MS
Southeast Sanitary Sewer Improvements
Pickering Firm, Inc. Project 25693.00

Plans, Specifications, and Contract Documents

TO: ALL PLANHOLDERS

FROM: Jonathan McLeod, PE

DATE: Thursday, 28 April 2022

The Plans, Specifications, and Contract Documents for this Project shall be amended as follows:

ADDENDUM #1

BIDDING DOCUMENTS

1. Bid Opening

Revised Bid Opening Date to May 10, 2022 at 10:00 a.m.

New cutoff for questions will be May 4th at 5:00 p.m.

PLANS & SPECIFICATIONS

1. Specification Section 02731 Wastewater Gravity Mains and Appurtenances – Replace #4, Part 2.04 Precast Concrete Manholes with the following:

Unless otherwise specified, manholes shall be precast with a crystalline waterproofing agent and the interior surface of all precast manholes lined with 24 mills, minimum, coal tar epoxy.

2. Replace Note 27, Line 4 on G0.03 with the following:

12" Lime Treatment, Class C, 6 Percent @ 95% Standard Proctor

CLARIFICATIONS

1. Service Connections by Licensed Plumber

A licensed plumber must make the final connection to the residence; however, the contractor may lay pipe from right-of-way to the point of connection.

2. Engineer's Opinion of Probable Construction Cost

\$1,300,000 – \$1,600,000

ITEMS IN CONFLICT WITH THIS ADDENDUM ARE HEREBY DELETED.

THIS ADDENDUM IS TO BE ACKNOWLEDGED BY THE BIDDER ON THE BID FORM.

Pickering Firm, Inc.



Jonathan McLeod, PE
28 April 2022

