

SHAHER | ZAHNER | ZAHNER
OFFICE OF ARCHITECTURE

July 11, 2022

GS# 361-009 Renovations & Repairs

War Memorial Building (Office of Capitol Facilities) (Department of Finance and Administration)

Jackson, MS

Addendum No. 4

This Addendum forms part of the Contract Documents for the above referenced project. All other requirements of the original Contract Documents shall remain in effect except as specifically modified in this Addendum. Bidder is to acknowledge receipt of this Addendum with their bid proposal. Failure to do so may subject the Bidder to disqualification. This Addendum is issued to all known Plan Holders.

1. Clarifications:

- a. Wall Tile 1 (WT-1) size is shown graphically as a hatch pattern, not the actual tile size, in the interior elevations. The tile size is scheduled on A610 and is indicated in the specifications.
- b. Light Fixture 23, existing wall sconce: The existing wall sconce is historic and original to the building. The restoration work shall be undertaken by an experienced craftsman, and care shall be taken to protect all the existing components of the fixture. The design intent is that the glass supports and associated hardware shall be repaired and/or replaced to provide a sound, secure fixture as part of the restoration scope of work. The intent is that the existing glass shade panels shall be retained and reused – only missing or broken glass shall be replaced.

Contents: This addendum consists of 1 (8 ½" x 11") sheets

End of Addendum No. 4 for:

GS# 361-009 Renovations & Repairs, War Memorial Building

