

7 October 2022





ADDENDUM NO. 04

NOTICE TO ALL DOCUMENT HOLDERS:

The following additions, deletions, changes and clarifications to the drawings and specifications are to be included as part of the Contract Documents.

CLARIFICATION

ITEM NO. 01 ALTERNATE 01 EARTHWORK

CLARIFICATION: The 12" of liming mentioned in the Geotechnical Report - Section 5.6 Guideline

Pavement Recommendations is not required under the Alternate 01 walking trail.

ITEM NO. 02 MILL AND OVERLAY

CLARIFICATION: All mill and overlay work to be at a depth of 1.5".

ARCHITECTURE

ITEM NO. 03 A100 – ARCHITECTURAL SITE PLAN


REPLACE sheet with the attached **A100.**

ADDS scope related to fencing at entry gate: demolition of portion of existing fencing and installation

of new fencing to match existing. Swing gates to remain in place.

cc: All Document Holders

File 0619





GS# 610-012 **MDWFP** LEFLEUR'S BLUFF **PARK IMPROVEMENTS** (PHASE 2)

MISSISSIPPI DEPARTMENT OF WILDLIFE, FISHERIES, AND PARKS

Riverside Park Circle Jackson, MS 39202

7/29/22

CONSTRUCTION DOCUMENTS

WBA # 0619

REVISIONS

 NO.
 DESCRIPTION
 DATE

 1
 ADDENDUM 02
 9.23.22

 2
 ADDENDUM 04
 10.7.22

