

BURRIS/WAGNON ARCHITECTS, P.A.

500L EAST WOODROW WILSON AVENUE JACKSON MS 39216 PH 6019697543 FAX 6019699374

28 November 2022

ADDENDUM NO. 2

Re: **Update Lakeland Medical Building
(University of Mississippi Medical Center)
Jackson, MS
Project No. 21LP102
IHL#209-582**



Bid Date: Thursday, December 1, 2022 (2:00 P.M)

NOTICE TO ALL DOCUMENT HOLDERS:

The following additions, changes, and clarifications to the Specifications for the subject project are to be included as part of the Contract Documents, and thus amend the Scope of Work:

DRAWINGS

- Item No. 1: Refer to Sheet TS:
- A. At detail "2", note that "expansion material" shown is "existing to remain." Sealant and backer rod are new.
 - B. At "1", Parking Structure Upper Level Floor Plan, note that the "double-broadcast traffic coating at all aisles" description in legend refers to specifications Section 07 18 16/3.03/C./3., Wear Coat (at heavy duty areas).
 - C. At "1", Parking Structure Upper Level Floor Plan, assume that each spall shown at this plan is 12" long. The total linear footage of spall repair to include in Base Bid shall equal *number of spalls shown x 12"*. *The total linear footage of spall repair may be reapportioned to other spalls (in addition to those marked on plan).*
- Item No. 2: Refer to Sheet 5.0, Unit Price #2, and clarify that each spall shall be assumed to be 12" in length.

No other items in this addendum.

Sincerely,

A handwritten signature in blue ink that reads "Bill Burris".

Bill Burris, AIA
BURRIS/WAGNON ARCHITECTS, P.A.

End of Addendum No. 2