



13 February 2024

Wine Room Roof Replacement and Parking Lot Addition
Mississippi Department of Revenue
Architect's Project Number 23-010
Bid Date: Thursday February 15, 2024 @2pm

ADDENDUM NO. 01

NOTICE TO ALL DOCUMENT HOLDERS:

The following additions, deletions, changes and clarifications to the drawings and specifications are to be included as part of the Contract Documents.

SPECIFICATIONS

ITEM NO. 01

WATERPROOF COATING BASIS OF DESIGN

REFERENCE ALSO DETAIL 3/A100 TYPICAL ROOF PARAPET DETAIL

CLARIFICATION: Waterproof Coating system to be installed at tops and backsides of parapet walls shall be equivalent to one of the following.

Acceptable Manufacturers/products:

1. Sherwin Williams - Sherlastic Elastomeric Coating
2. Benjamin Moore - Ultra Spec Elastomeric Coating
3. Sika USA - SikaGuard 515 100% Acrylic Elastomeric Coating

Notes:

- Products shall be installed in strict accordance with manufacturer's instructions.
- Prime all existing surfaces with compatible primer
- Install (2) coats; ea. in manufacturer's recommended mil thickness
- Install additional coats as necessary to achieve the manufacturer's overall recommended coating Dry Film thickness.

ITEM NO. 02

JOINT SEALANT BASIS OF DESIGN

REFERENCE ALSO DETAIL 3/A100 TYPICAL ROOF PARAPET DETAIL

CLARIFICATION: Sealant to be installed in precast joints at tops and backsides of parapet walls shall be equivalent to the following:

Acceptable Manufacturers/products:

1. Dow Chemical Company - DOWSIL 756 SMS Building Sealant
2. Pecora - 864 NST Sealant
3. Tremco - Tremsil 200 Sealant

Notes:

- Products shall be installed in strict accordance with manufacturer's instructions.
- Do not install elastomeric coating over sealant.

NO MORE ITEMS

Encl: none

cc: All Document Holders ; File 23-010