

**PEA SHELLING FACILITY  
ALCORN STATE UNIVERSITY  
Mound Bayou Technology & Transfer Center  
Project Number: 2019-001**

**Addendum No. 2**

From: Vernell Barnes, Architect  
1409 Watkins Street  
Natchez, MS 39120  
Telephone: 770.605.9829  
Fax: 770.987.5208

09June2020

The following additions, changes, clarifications, and substitutions to the specifications and drawings of the original plans and specifications dated January 21, 2020, are to be included as part of the contract documents. Receipt of this addendum shall be acknowledged in the bid proposal form.

**Bid Date:** The bid date, time and location shall remain unchanged.

**GENERAL INFORMATION:**

No items

**REFER TO THE SPECIFICATIONS:**

**ARCHITECTURAL:**

- |                |   |
|----------------|---|
| Item No. 1     | Document 01900 – Division One Supplement  |
| <u>Delete:</u> | Delete Add Alternate Number One (1) in its entirety.<br>Part 3 – Alternate Supplement, 3.01 Description of Alternates, Item “A”.  |
| Item No. 2     | Division 5 – Metals   |
| <u>Revise:</u> | Revise Section 05 5200, Part 2.02-A-3 to read as follows:<br>3. Posts: 4” square with .25” wall.  |
| Item No. 3     | Division 8 - Openings   |
| <u>Delete:</u> | Delete specification Sections numbered 08 1113, 08 3323 and 08 7100 in their entirety.  |
| Item No. 4     | Division 13 – Special Construction  |
| <u>Delete:</u> | Delete all references to wall panels and/or wall insulation in Section 13 3419.<br>Delete Parts 2.06, 3.04, 3.06, and 3.07-C.   |
| Item No. 5     | Division 13 – Special Construction  |
| <u>Revise:</u> | Revise Section 13 3419, Part 2.05-A-1 to read as follows:<br>1. Material: Zinc-coated (galvanized) or aluminum-zinc alloy-coated steel sheet, 0.020-inch (0.511-mm) nominal uncoated steel thickness. |

Prepainted by the coil-coating process to comply with ASTM A755/A755M.

**REFER TO THE DRAWINGS:**

Item No. 1                      Refer to sheets A1-1 and A2-1.

Delete                      Delete all references to Additive Alternate Number1.

End of Addendum Number Two



Vernell E. Barnes, AIA  
Vernell Barnes, Architect

