

Addendum #4

FOR

***City of Pearl Parks and Recreation Phase 2:
City Park Improvements
Pearl, MS***

June 16, 2020

PICKERING FIRM, INC.
2001 Airport Parkway, Suite 201
Flowood, MS 39232
601-956-3663



DATE: June 16, 2020

PROJECT: **City of Pearl Parks and Recreation Phase 2: City Park Improvements
Pearl, MS**

NOTICE TO ALL BIDDERS: This Addendum modifies (changes, adds to, deletes from) and/or interprets the Bidding Documents (Project Manual and/or Drawings, as indicated), and becomes part of the Contract Documents when the Agreement between the Owner and Contractor is executed.

Drawings

Civil

1. Building demolition at Jenkins Park shall be performed by the City of Pearl.

Structural

1. All of the buildings, except for the tennis pavilion, should have a 4" layer of compacted stone below the slab.
2. Earthwork for each building, as specified in specification 312000 Earthwork for Structures, shall be included in the lump sum price for that particular building item.

Electrical

1. Contactor C4 at Guyton Park and contactor C5 shall be located next to the panel.
2. A photocell is not required for contactor C6.
3. The existing electrical panel at Guyton Field (currently labeled as key note #4 on ED1.1) shall be removed by the City of Pearl.
4. Communication work for buildings is rough-in-only.